

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1209:209 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: System Sensor, 3825 Ohio Avenue, St. Charles IL 60174
Contact: *Trish Linhart (630) 377-6674 Fax (630) 377-7245

DESIGN: Models S2475 strobe lights. Model number may be followed by suffix RLP, ALP, GLP, or BLP, may or may not be followed by W. Intended for wall mount only. The suffix-P for plain plastic housing.

Models DS2475 strobe lights. Model number may be followed by suffix -W(white color) and/or A, R, B, C or G. Intended for wall or ceiling mount.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20 - 30 VDC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as strobe lights non-hearing impaired when used with separately listed compatible fire alarm control units. For indoor use only.

NOTE: Not to be used as a visual public mode alarm notification appliance.

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 16, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager